


CUADRO CLIMATIZACIÓN



CONSUMOS	CONTROL	REYQI2T PI_3	REYQI2T P2_2	REYQI2T PB_2	REYQI4T P3_3	REYQI4T PB_1	REYQI6T PI_1	REYQI6T PI_2	REYQI6T P3_1	REYQI6T P3_2	REYQI8T P2_1	REYQI8T P3_1	REYQ8T P2_3	RXYQI2T PB_SA
FASE	800	17.434	29.605	17.434	23.092	23.092	26.816	26.816	26.816	26.816	29.908	29.908	12.553	23.092
PCAL (W)	400	400	400	400	400	400	400	400	400	400	400	400	400	400
UN (V)	1.22	27.96	47.48	27.96	37.03	37.03	43.01	43.01	43.01	43.01	47.96	47.96	20.13	37.03
IB (A)	25.48	33.67	60.06	33.67	43.68	43.68	60.06	60.06	60.06	60.06	60.06	60.06	25.48	43.68
IZ (A)	2.5	4	10	4	6	6	10	10	10	10	10	10	2.5	6
SF (mm²)	15.00	17.00	17.00	17.00	15.00	17.00	15.00	15.00	15.00	15.00	17.00	3.83	17.00	20.00
LTOT (M)	4.76	15.00	17.00	17.00	15.00	17.00	15.00	15.00	15.00	15.00	17.00	3.83	17.00	20.00
LCDT (M)	4.76	15.00	17.00	17.00	15.00	17.00	15.00	15.00	15.00	15.00	17.00	3.83	17.00	20.00
CDT_CIRC (%)	0.0177	0.8549	0.6513	0.9689	0.7585	0.8596	0.5110	0.5110	0.5110	0.5110	0.6593	0.1484	1.1044	1.0113
CDT_ACUM (%)	0.0177	0.8549	0.6513	0.9689	0.7585	0.8596	0.5110	0.5110	0.5110	0.5110	0.6593	0.1484	1.1044	1.0113